



NOTES:

1. THIS DETAIL SHOULD BE USED WHEN THERE IS ANY POSSIBILITY DIFFERENTIAL MOVEMENT WILL OCCUR BETWEEN THE DECK AND A VERTICAL SURFACE. THE WOOD MEMBERS SHOULD NOT BE FASTENED TO THE WALL.
2. WHEN POTENTIAL FIRE HAZARDS CAN BE MITIGATED, NRCA CONSIDERS IT ACCEPTABLE TO INSTALL TORCH-APPLIED POLYMER-MODIFIED BITUMEN SHEET OVER THE SPECIFIED BACKER FLASHING USING THE DIRECT TORCHING METHOD PROVIDED LOW OUTPUT (50,000 BTU OUTPUT OR LESS) TORCHING EQUIPMENT IS USED. WHEN POTENTIAL FIRE HAZARDS CANNOT BE ADEQUATELY MITIGATED, TORCH-APPLIED POLYMER-MODIFIED BITUMEN SHEET SHALL BE INSTALLED USING INDIRECT TORCHING METHODS, SUCH AS THE TORCH-AND-FLOP APPLICATION METHOD.
3. FOR ROOF SYSTEMS WITH FACTORY-APPLIED GRANULE SURFACING, PROPERLY PREPARE CAP SHEET TO RECEIVE FLASHING.
4. REFER TO THE ARCHITECTURAL METAL FLASHING SECTION OF NRCA ROOFING MANUAL: ARCHITECTURAL METAL FLASHING, CONDENSATION CONTROL AND REROOFING--2010 FOR DESIGN, JOINERY AND SECUREMENT OPTIONS FOR COUNTERFLASHING.
5. REFER TO SECTION 10.1--INFORMATION APPLICABLE TO ALL CONSTRUCTION DETAILS FOR ADDITIONAL INFORMATION.



**BASE FLASHING AT ROOF-TO-WALL EXPANSION JOINT
(TORCH-APPLIED FLASHING SYSTEMS)**

2011

NOT DRAWN TO SCALE

MB(T)-7